

Delaware Department of Transportation

QUESTIONS AND ANSWERS

T201353101.01

MID COUNTY MAINTENANCE FACILITY PAVING-FTA STATE OF GOOD REPAIR GRANT

Wednesday, August 14, 2013

Q #	Question	Answer
4	Other than the 101 LF of curb that we are removing where the tie-in to the new training area is what are we removing under item 758000?	There is an existing concrete pad (shown on the plans) that is close to the new pad location. We added extra quantity in case the contractor needed to remove a portion of the concrete pad in order to excavate and construct the new pad under 758000.

Tuesday, August 13, 2013

3	The question was asked about the Grass Filter Strip Detail, not quite sure about the response, no specific detail pertaining to the grass filter strip on sheet (5) nor do I see a pay item. Please advise.	The grass filter strip is shown complete as detail "D" in the construction detail on sheet 5 with two items: Item 732002, Topsoil 6" Depth; and Item 734013, Permanent Grass Seeding, Dry Ground.
---	---	---

Tuesday, August 06, 2013

Saturday, August 03, 2013

2	On Plan Sheet 5 a grass filter strip is shown around the perimeter of the new paved bus pad. What is the detail of this grass filter strip.	The grass filter strip detail is complete as shown on sheet 5.
1	Per plan sheet 3 and Note 6 under Misc it states that Cross-Sections are available for the project.	Cross Sections used in the preparation will be made available upon request post-award.